

ARTICLE II. CONNECTION TO SEWER

Sec. 6.4-20. Sewer connection required

(a) Connection to a public sewer system shall be required for all proposed lots, new development, additions, or remodels that propose to generate wastewater, and for existing structures requiring repairs to the septic system if sewer is available. Sewer is available if: 1) it is within 200 feet of the property line, and 2) the structure to be served is within one thousand feet of the property line closest to the sewer or of another structure on the same property that is connected to the sewer, and 3) there is willingness by the agency in control of the sewer to permit connection to the sewer main.

(b) No permit for installation, repair, replacement or expansion of a septic system shall be issued if sewer is available. Exception: permits for repairs to the solid pipe of an on-site sewage disposal system shall be allowed if sewer is available provided that a nuisance is not created or maintained and the repair will comply with these standards.

(Ord. No. 1609, §18)